

CORRIGENDUM - I : RFP No : NIL dated 14 Dec 2024

**REQUEST FOR PROPOSAL (RFP): AMC of 1 x 10KVA Emerson, 1 x 10 KVA AVO
and 1 x 30 KVA Power ON Online UPS**

1. The following amendments may kindly be noted in the subject RFP:

For:

Scope of Work

Refer para 10 of RFP please add the following points.

1. **Preventive Maintenance:**

- a. The L1 vendor must perform preventive maintenance of the UPS every quarter.
- b. The first preventive maintenance should commence within a week of receiving the work order.
- c. During preventive maintenance, the vendor must carry a blower for cleaning the UPS.

Breakdown Management:

- a. In the event of a major breakdown, the vendor must provide a standby unit within 48 hours.
- b. All breakdown calls must be attended to within 48 hours, with unlimited calls allowed during the AMC period.
- c. If spare parts for the UPS are unavailable, the vendor must provide documented proof of their unavailability.

For:

Documents to be Submitted

Refer para 11 of RFP please add the following points.

- a. A minimum of three work orders from government organizations or the educational sector for the AMC of UPS.

Please add following as Para 12 of RFP

Payment Terms :

Quarterly Advance.

Rest No change , *For any quires, requested to reach us.*

Yours faithfully,

A. Saha
Dr. Anindya Saha,
Presiding Officer

Army Institute of Management, Kolkata

Dated 19 Dec 2024